

## FIRE & RESCUE SERVICE LICENSE

L.Dis. NO.3253/B1/2024

DATE: 09.07.2024

C.R.PNo:153

O/o District Officer,  
Fire and Rescue Services,  
Thanjavur District, Thanjavur.

Fire License is hereby granted under section 13 of the Tamil Nadu Fire Service Act 1985, Tamil Nadu Fire Service Rules 1990 Appendix III, National Building Code of India Part-IV, Fire and Life Safety 2016, and Tamil Nadu Combined Development and Building Rules 2019, G.O.Ms.No.18, Date:04.02.2019, to run a **College** in the name and style of "ANNAI COLLEGE OF ART & SCIENCE (ACAS-MBA)" (Mention whichever is applicable) within the jurisdiction of **Kumbakonam Municipality / Panchayat / Corporation** at the premises R.S.No.112/3B, 113/1, 113/2, 114/1, Kovilachery Village, Kumbakonam Taluk, Thanjavur District Subject to the condition noted there on and such conditions as may be prescribed. This premise was inspected by Station Officer, Fire and Rescue Station, Kumbakonam on 09.07.2024. Vide inspection Report No.399/2023 and date 11.07.2024

### CONDITIONS

- 1 Hose Reel System should be installed in all floors of the Building, Hydrant System should be installed in the Institute premises.
- 2 All the Fire Extinguishers have to be recharged and maintained periodically as per code practice in 2190 / 2010.
- 3 All fixed installation should be maintained properly as per NBC-2010.
- 4 Register of Fire Extinguisher and Register of Mock drill should be maintained as per form II & III respectively.
- 5 (off site emergency) Mock drill should be conducted every year.
- 6 Elementary Fire Fighting training should be given to the employee's from Fire Service Department.
- 7 House Keeping should be neat and clean.
- 8 This Certificate is valid for one year from the date of issue.
- 9 Non compliance of the above conditions invites the automatic cancellation of this License.
- 10 In Compliance to section 3.2 of BIS 12459:1988-code of practice for Fire Safety in cable regularization, a transparent fire retardant coating of 1 meter shall be applied on all electrical cables at both sides of termination points in every electrical panel and all the cables in the distribution box.

(Office Seal with Date)



  
District Officer,  
Fire and Rescue service,  
Thanjavur District, Thanjavur.

  
15/7

To: Principal,  
Annai College of Arts & Science,  
Kovilacheri, Kumbakonam, Thanjavur.

Copy: Deputy Director, Central Region, Tiruchirapalli.